




INDEX

1 X GHG 448 ENCLOSURE
1 X ISOLATOR 40A 4P 400V


1 X START (NO+NC BLOCK)
1 X STOP (NO+NC BLOCK)
1 X AMMETER C/T 1AMP CT
(SCALE : TBA)

PADLOCKABLE IN OFF POSITION

1 X M20 TAPPED ENTRY
2 X M25 TAPPED ENTRY

BRASS GLAND PLATE + 8MM EARTH STUD
1 X BREATHER GLAND M20

SWITCHING ARRANGEMENT



Drawing accepted by:

Signed:

Date:

Description:  40AMP 4POLE ISOLATOR CONTROL STATION WITH START AND STOP PB WITH AMMETER

Project: MASTER DRAWING

Crouse-Hinds
by **Eaton**

REF NO.
190819VM0846

CERTIFICATION
ZONE 1 & 21

REVISION
REV.000

CONTACT
NEVILLE BELL
031 464 0023

EXB
YOUR HAZARDOUS AREA SOLUTION